

The Poultry Post

May 2007

Summertime Checklist

- ✓ Check all fan belts for tightness for optimal efficiency
- ✓ Clean fan blades and louvers to prevent restricted air flow
- ✓ Clean cool cell pads with a recommended cleaner to ensure maximum water distribution
- ✓ Patch or replace torn curtain material to ensure correct static pressure
- ✓ Test all alarm systems and replace batteries
- ✓ Make sure generator has fuel in case of emergency
- ✓ Clean all drinker lines and flush, replace any leaking nipples or regulators
- ✓ Keep spare fan motors, belts, pulleys, and other crucial parts on farm for quick replacement
- ✓ Check air inlets to ensure proper closure when using tunnel ventilation



Contact:

Johnnie Whitmire

Assistant Extension Agent-Poultry

North Central Region

Hill Farm Research Station

11959 Hwy 9

Homer, LA 71040

Office-318-927-2578 Ext.224

Cellular: 318-355-2646

Visit our Web site: www.lsuagcenter.com

Louisiana State University Agricultural Center - William B. Richardson, Chancellor

Louisiana Agricultural Experiment Station – David Boethel, Vice Chancellor and Director

Louisiana Cooperative Extension Service - Paul D. Coreil, Vice Chancellor and Director

Issued in furtherance of Cooperative Extension work, Acts of Congress of May 8 and June 30, 1914, in cooperation with the United States Department of Agriculture.

The Louisiana Cooperative Extension Service provides equal Opportunities in programs and employment.